

ganization Plan of November 25, 2002, as modified, set out as a note under section 542 of Title 6.

§ 2225. Fire prevention and control guidelines for places of public accommodation

(a) Contents of guidelines

The guidelines referred to in sections 2224 and 2226 of this title consist of—

(1) a requirement that hard-wired, single-station smoke detectors be installed in accordance with National Fire Protection Association Standard 74 or any successor standard to that standard in each guest room in each place of public accommodation affecting commerce; and

(2) a requirement that an automatic sprinkler system be installed in accordance with National Fire Protection Association Standard 13 or 13-R, or any successor standard to that standard, whichever is appropriate, in each place of public accommodation affecting commerce except those places that are 3 stories or lower.

(b) Exceptions

(1) The requirement described in subsection (a)(2) of this section shall not apply to a place of public accommodation affecting commerce with an automatic sprinkler system installed before October 25, 1992, if the automatic sprinkler system is installed in compliance with an applicable standard (adopted by the governmental authority having jurisdiction, and in effect, at the time of installation) that required the placement of a sprinkler head in the sleeping area of each guest room.

(2) The requirement described in subsection (a)(2) of this section shall not apply to a place of public accommodation affecting commerce to the extent that such place of public accommodation affecting commerce is subject to a standard that includes a requirement or prohibition that prevents compliance with a provision of National Fire Protection Association Standard 13 or 13-R, or any successor standard to that standard. In such a case, the place of public accommodation affecting commerce is exempt only from that specific provision.

(c) Effect on State and local law

The provisions of this section shall not be construed to limit the power of any State or political subdivision thereof to implement or enforce any law, rule, regulation, or standard concerning fire prevention and control.

(d) Definitions

For purposes of this section, the following definitions shall apply:

(1) The term “smoke detector” means an alarm that is designed to respond to the presence of visible or invisible particles of combustion.

(2) The term “automatic sprinkler system” means an electronically supervised, integrated system of piping to which sprinklers are attached in a systematic pattern, and which, when activated by heat from a fire, will protect human lives by discharging water over the fire area, and by providing appropriate warning signals (to the extent such signals are required by Federal, State, or local laws or

regulations) through the building’s fire alarm system.

(3) The term “governmental authority having jurisdiction” means the Federal, State, local, or other governmental entity with statutory or regulatory authority for the approval of fire safety systems, equipment, installations, or procedures within a specified locality.

(Pub. L. 93-498, §29, as added Pub. L. 101-391, §3(a), Sept. 25, 1990, 104 Stat. 748; amended Pub. L. 102-522, title I, §105, Oct. 26, 1992, 106 Stat. 3411; Pub. L. 105-108, §3(1)–(3), Nov. 20, 1997, 111 Stat. 2264.)

AMENDMENTS

1997—Subsec. (a)(1). Pub. L. 105-108, §3(1), inserted “or any successor standard to that standard” after “Association Standard 74”.

Subsec. (a)(2). Pub. L. 105-108, §3(2), inserted “, or any successor standard to that standard” before “, whichever is appropriate,”.

Subsec. (b)(2). Pub. L. 105-108, §3(3), inserted “, or any successor standard to that standard” after “Association Standard 13 or 13-R”.

1992—Subsecs. (b) to (d). Pub. L. 102-522, §105(a), added subsec. (b) and redesignated former subsecs. (b) and (c) as (c) and (d), respectively.

Subsec. (d)(3). Pub. L. 102-522, §105(b), added par. (3).

§ 2225a. Prohibiting Federal funding of conferences held at non-certified places of public accommodation

(a) In general

No Federal funds may be used to sponsor or fund in whole or in part a meeting, convention, conference, or training seminar that is conducted in, or that otherwise uses the rooms, facilities, or services of, a place of public accommodation that does not meet the requirements of the fire prevention and control guidelines described in section 2225 of this title.

(b) Waiver

(1) In general

The head of an agency of the Federal Government sponsoring or funding a particular meeting, convention, conference, or training seminar may waive the prohibition described in subsection (a) of this section if the head of such agency determines that a waiver of such prohibition is necessary in the public interest in the case of such particular event.

(2) Delegation of authority

The head of an agency of the Federal Government may delegate the authority provided under paragraph (1) to waive the prohibition described in subsection (a) of this section and to determine whether such a waiver is necessary in the public interest to an officer or employee of the agency if such officer or employee is given such authority with respect to all meetings, conventions, conferences, and training seminars sponsored or funded by the agency.

(c) Notice requirements

(1) Advertisements and applications

(A) Any advertisement for or application for attendance at a meeting, convention, conference, or training seminar sponsored or